

Nachhallzeit

Projekt: VS Lerchengasse

Messort: Turnsaal


Vorher (08.04.2021):

Frequenz	Nachhallzeit
100 Hz	1,32 s
125 Hz	1,35 s
160 Hz	1,40 s
200 Hz	1,48 s
250 Hz	1,60 s
315 Hz	1,86 s
400 Hz	2,10 s
500 Hz	2,30 s
630 Hz	2,44 s
800 Hz	2,49 s
1 kHz	2,55 s
1.25 kHz	2,45 s
1.6 kHz	2,31 s
2 kHz	2,17 s
2.5 kHz	2,06 s
3.15 kHz	1,80 s
4 kHz	1,45 s

Nachher (09.08.2021):

Frequenz	Nachhallzeit *)
100 Hz	1,05 s
125 Hz	1,09 s
160 Hz	1,11 s
200 Hz	1,13 s
250 Hz	1,18 s
315 Hz	1,19 s
400 Hz	1,19 s
500 Hz	1,16 s
630 Hz	1,17 s
800 Hz	1,22 s
1 kHz	1,22 s
1.25 kHz	1,20 s
1.6 kHz	1,18 s
2 kHz	1,10 s
2.5 kHz	1,11 s
3.15 kHz	1,10 s
4 kHz	1,03 s

*) inkl 8 geöffneter Lampenspiegel



Turnsaal Mödling Lerchengasse

